

Report Run Date: 8/27/19

NPDES ID(s) Entered: CA0037664;CA0037681

Issued By: State

Status Date Between: 1/1/2013 12:00:00 AM and 8/27/2019 11:19:02 AM

ENFORCEMENT ACTIONS

CA0037664 SOUTHEAST WPCP, NORTH POINT WWF, BAYSIDE WWF

Issued By	Enforcement Action Identifier	Enforcement Action Name	Enforcement Action Type	Forum	Status Date	Achieved Date	Cash Civil Penalty Amount Sought
State	CA-2013-1082	SAN FRANCISCO PUC WW ENTERPRISE - EPL	State CWA Penalty AO	Administrative - Formal	10/03/2013		\$6,000

CA0037681 OCEANSIDE WWTP

Issued By	Enforcement Action Identifier	Enforcement Action Name	Enforcement Action Type	Forum	Status Date	Achieved Date	Cash Civil Penalty Amount Sought
State	CA-0216-1034	SF - OCEANSIDE WATER POLLUTION CONTROL PLANT - ACL	State CWA Penalty AO	Administrative - Formal	03/29/2017		\$611,100

Single Event Violations

CA0037664 SOUTHEAST WPCP, NORTH POINT WWF, BAYSIDE WWF
San Francisco, City and County of

Single Event Start Date	Single Event End Date	Single Event Violation Code	Single Event Violation Desc	RNC Detection Code	RNC Detection Date	RNC Resolution Code	RNC Resolution Date
09/14/2017		D0017	Permit Violations - Violation Specified in Comment At approximately 10:15 a.m. on September 14, 2017, SFPUC discovered fully treated, final effluent leaking from an air relief valve in the manhole at the northeast intersection of Islais Creek and 3rd Street and discharging into Islais Creek. The air relief valve connects to the Southeast Plant final effluent outfall pipe. The leak was caused by a misaligned gasket and was fixed on September 15, 2017. Approximately 0.94 million gallons of fully treated, final effluent were discharged to Islais Creek.				
10/20/2017		D0017	Permit Violations - Violation Specified in Comment Approximately 228,600 gallons of fully-treated, chlorinated and dechlorinated effluent were discharged to the Quint Street outfall from 12:37 a.m. to 1:15 a.m. during a power outage. SFPUC shut down the plant at that time and brought it back online at approximately 7:00 a.m. after power was restored at about 6:00 a.m. See 5-day report dated October 27, 2017.				
03/13/2018		D0017	Permit Violations - Violation Specified in Comment For about one minute beginning at about 6:00 a.m., approximately 1,500 to 2,000 gallons of primary-treated, chlorinated and dechlorinated plant effluent, was discharged through the Quint Street outfall (instead of the Pier 80 outfall) because an effluent gate did not open during the plant's transition to wet weather mode. The primary effluent overflowed from an open hatch and flowed overland to the effluent channel where it mixed with secondary-treated, chlorinated and dechlorinated effluent. See 5-day report dated March 20, 2018.				
10/18/2018		D0017	Permit Violations - Violation Specified in Comment Secondary-treated, chlorinated, and dechlorinated wastewater discharged to Islais Creek from leak in the 36-inch force main from the Booster Pump Station to Discharge Point 001 (Pier 80 Outfall). Upwelling was first discovered on October 18, 2018, and the leak is ongoing as of December 26, 2018. On November 3, 2018, divers discovered that only the 36-inch force main is leaking. 5-day report received October 25, 2018, and subsequent updates received via email on November 1, 8, 16, 29, and December 7, 2018.				